



WH Technology Corp.

CERTIFICATE OF COMPLIANCE

Applicant : Weintek Labs., Inc.
Address : 3F , No. 910, Zhongzheng Rd., Zhonghe Dist., New Taipei City, Taiwan
Model No. : cMT-FHDX-220
Serial No. : cMT-FHDX-xxx(x= 0~9, A~Z , a~z , blank or dash)
Brand Name : Weintek, Weinview, EasyView
Type of Equipment : HMI (Human Machine Interface)
Report NO. : WH-CE-E20032401
WH-CE-E20032401-1

EMC Standard:

EMI :

EN 55032 : 2015+AC:2016

EN 61000-6-4:2007+A1:2011

EN 55011:2016

EN 61000-3-2 : 2014

EN 61000-3-3 : 2013

AS/NZS CISPR 32 : 2015

EMS :

EN 55024 : 2010+A1:2015

EN 61000-6-2:2005

IEC 61000-4-2 : 2008

IEC 61000-4-3 : 2006+A1:2007+A2:2010

IEC 61000-4-4 : 2012

IEC 61000-4-5 : 2014+A1:2017

IEC 61000-4-6 : 2013/COR1:2015

IEC 61000-4-8 : 2009

IEC 61000-4-11 : 2004+A1:2017

Deviation from Applicable Standard

According to the applicant's declaration this EUT is a class A product

The above equipment was tested by WH Technology Corp. for compliance with the requirements set forth in the EUROPEAN COUNCIL Directive 2014/30/EU and the technical standards mentioned above. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance.

Approved By:

Bell Wei / Manager



Issued Date: APR. 13, 2020